

| | |
|----|--------------|
| 形式 | FPW2-LED814N |
|----|--------------|





| | |
|------|--------|
| 光源 | — |
| 定格光束 | 900 lm |

| | |
|------|---------|
| 器具効率 | 100.0 % |
| 下方効率 | 59.1 % |
| 上方効率 | 40.9 % |

| | | | |
|--------|-----|---|--|
| 最大取付間隔 | | | |
| A断面 | 1.9 | H | |
| C断面 | 1.8 | H | |
| B断面 | 1.6 | H | |

| 角度 [deg.] | 光度 [cd/1000lm] |
|-----------|----------------|
| 0 | 183 |
| 10 | 182 |
| 20 | 178 |
| 30 | 170 |
| 40 | 154 |
| 50 | 129 |
| 60 | 96 |
| 70 | 59 |
| 80 | 22 |
| 90 | 0 |
| 100 | 16 |
| 110 | 42 |
| 120 | 69 |
| 130 | 91 |
| 140 | 106 |
| 150 | 114 |
| 160 | 118 |
| 170 | 120 |
| 180 | 120 |



| 照明率表 | | 平均照度 = 台数 * 照明率 * 保守率 * 900.0 / (間口 * 奥行き) | | | | | | | | | | | | | | | | | |
|-------------|------|--|------|------|------|------|------|------|------|------|------|------|------|------|----|----|---|---|--|
| 床(%) | | 10 | | | | | | | | | | | | 0 | | | | | |
| 天井(%) | | 80 | | | | 60 | | | | 40 | | | | 20 | | | | 0 | |
| 壁(%) | | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 | | |
| 室 指 数 | 0.50 | 0.35 | 0.28 | 0.24 | 0.31 | 0.26 | 0.22 | 0.28 | 0.23 | 0.20 | 0.24 | 0.20 | 0.17 | 0.14 | | | | | |
| | 0.70 | 0.48 | 0.41 | 0.36 | 0.43 | 0.37 | 0.33 | 0.38 | 0.33 | 0.30 | 0.33 | 0.30 | 0.27 | 0.23 | | | | | |
| | 1.00 | 0.62 | 0.55 | 0.50 | 0.55 | 0.50 | 0.46 | 0.50 | 0.46 | 0.42 | 0.44 | 0.41 | 0.39 | 0.34 | | | | | |
| | 1.25 | 0.70 | 0.64 | 0.59 | 0.63 | 0.58 | 0.55 | 0.56 | 0.53 | 0.50 | 0.50 | 0.48 | 0.46 | 0.41 | | | | | |
| | 1.50 | 0.75 | 0.70 | 0.66 | 0.68 | 0.64 | 0.61 | 0.61 | 0.58 | 0.56 | 0.55 | 0.53 | 0.51 | 0.45 | | | | | |
| | 2.00 | 0.82 | 0.78 | 0.75 | 0.74 | 0.71 | 0.69 | 0.67 | 0.65 | 0.63 | 0.60 | 0.58 | 0.57 | 0.51 | | | | | |
| | 2.50 | 0.87 | 0.83 | 0.80 | 0.78 | 0.76 | 0.73 | 0.70 | 0.68 | 0.67 | 0.63 | 0.61 | 0.60 | 0.54 | | | | | |
| | 3.00 | 0.89 | 0.86 | 0.84 | 0.80 | 0.78 | 0.76 | 0.72 | 0.71 | 0.69 | 0.64 | 0.63 | 0.62 | 0.56 | | | | | |
| | 4.00 | 0.92 | 0.90 | 0.88 | 0.83 | 0.81 | 0.80 | 0.74 | 0.73 | 0.72 | 0.66 | 0.65 | 0.65 | 0.57 | | | | | |
| | 5.00 | 0.94 | 0.92 | 0.90 | 0.84 | 0.83 | 0.82 | 0.75 | 0.74 | 0.74 | 0.67 | 0.66 | 0.66 | 0.58 | | | | | |
| 7.00 | 0.96 | 0.94 | 0.93 | 0.86 | 0.85 | 0.84 | 0.76 | 0.76 | 0.75 | 0.67 | 0.67 | 0.67 | 0.59 | | | | | | |
| 10.00 | 0.97 | 0.96 | 0.95 | 0.87 | 0.86 | 0.86 | 0.77 | 0.77 | 0.76 | 0.68 | 0.68 | 0.68 | 0.59 | | | | | | |